AMTEST
14603 NE 87th St
Redmond, WA 98052
(425) 885-1664

INORGANIC CHEMICALS (IOCS) REPORT FOR NITRATES

System ID No.: **40950K**	System Name: Lake Forest Park Water	
Lab/Sample No: 06600972	Date Collected: 1/19/01	DOH Source No: S05
Multiple Source Nos.:	Sample Type: D	Sample Purpose: I
Date Received: 1/19/01	Date Reported: 2/ 7/01	Supervisor: JB
	Date Analyzed: 1/31/01	Analyst:
County: King		Group: A
Sample Location: Shallow Well Transfer Pump House		
Send Report To: Lake Forest Park Water Distrct 4029 NE 178th Street Lake Forest Park, WA 98155	Bill To: Lake Forest Park Water Disrti 4029 NE 178th Street Lake Forest Park, WA 98155	

t

DOH#	ANALYTES	RESULTS	UNITS	SRL	TRIGGER	MCL	EXCEEDS TRIGGER	EXCEEDS MCL	METHOD/ANALYST	
	EPA REGULATED									
114	Nitrite-N	ND	mg/l	0.50	0.5	1.0	NO	NO	SM4500-NO2-B	KF
20	Nitrate-N	3.0	mg/l	0.50	5	10.	NO	NO	SM4500-NO3-F	KF
161	Total Nitrate/Nitrite	3.0	mg/l	0.50	5	10.	NO	NO	SM4500-NO3-F	KF

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).

Trigger Level: DOH Drinking Water Response Level. Systems with compounds detected at concentrations in excess of this level are required to take additional samples. Contact your regional DOH office for further information.

MCL (Maximum Contaminant Level): If the contaminant amount exceeds the MCL immediately contact your regional DOH office.

NA (Not Analyzed): in the amount column indicates this compound was not included in the ce current analysis.

ND (Not Detected): in the amount column indicates this compound was analyzed and not detected at a level greater than or equal to the SRL.

Comments: